

Brockway Area Sewage Authority

*501 Main Street
Brockway, PA. 15824*

*Office of the Manager
Phone (814)268-6565
Fax (814) 265-1300*

ENTERED
Office of Chief Counsel
January 14, 2026
Part of
Public Record

January 13, 2026

The Brockway Area Sewer Authority (BASA) is responding to the Petition filed by Lampwrights LLC (Lampwrights) on September 29, 2025 as we have been informed via Docket No. FD 36833. BASA was tentatively informed that the proposed rail is to be installed on portions of the old railroad grade where we have easements and existing sewer lines. The proposed rail cannot be installed over our sewer lines as no permanent structures are permitted within 10 feet of our sewer lines, which allows us to service and maintain the infrastructure.

Unless the proposed rail alignment has changed, BASA would not permit the proposed rail to run parallel to our existing infrastructure within 10ft of our existing sewer lines. Furthermore, any perpendicular crossing of any of our existing sewer lines would need to be modified to meet the requirements for a utility crossing under a rail line.

To date, BASA has not been officially approached by Lampwrights full intentions and proposed alignment for the rail system. It is imperative we have a full understanding of Lampwrights intentions and how this may affect our existing sewer infrastructure.

Thank you!

Brockway Area Sewage Authority

CC: Parties of Record